

On-site Co-generation Experience at Elettra

Andrea Galimberti
Sincrotrone Trieste - Elettra


on behalf of
Infrastructure Group of Sincrotrone Trieste

with the collaboration of
Collini S.p.A. – Trento – Italy
Landi S.p.A. – Bergamo - Italy
Energytech G.m.b.H./S.r.l – Bozen/Bolzano - Italy
UPB AS CH – Liestal – Switzerland
Trigenerazione S.r.l. – Padova – Italy
Bettoli S.r.L. – Treviso - Italy

Elettra Laboratory



Elettra Laboratory Layout: SRS & FEL



AGENDA

Facility Energy Requirements: Electricity – Heating - Cooling

Business-as-usual: energy/cost balance with a traditional plant

More than co-generation: UPS & co-generation

The trigeneration plant: Layout & performances

Co-generation: energy/cost balance with co-generation

First operational experience: a different plant management

Critical issue: interfacing old pipe system

Benefits: costs & CO₂ reduction

Laboratory Energy Requirements



2011

Electricity: 49 GWh





Cooling: 28.6 GWh_f



Heating: 6.4 GWh_t

Natural Gas: 800,000 Smc



2011

Environmental Cost

CO₂: 32,670 tCO₂: 2,160 t

Energy Cost


EE: 6,700,000€

Gas: 320,000€

Total: 7,020,000€

Il Bilancio elettrico e le fonti rinnovabili in Italia a fine 2010

Nel 2010 la richiesta di energia elettrica sulla rete in Italia è risultata pari a 330,5 TWh, circa il 3% in più rispetto all'anno precedente.



* Produzione netta: è la produzione linda al netto dei servizi ausiliari e dei consumi da pompaggio

1) Include la parte biodegradabile dei rifiuti

2) Al netto dei rifiuti solidi urbani non biodegradabili, contabilizzati nella termica tradizionale

3) Carbone + Lignite


4) Al netto della produzione da biomasse, biogas e bioliquidi e dei consumi da pompaggio

Italian EE Balance 2010


Natural Gas: 44.9%


Trigeneration Concept

Trigeneration



Elettra Plant Layout: A Distributed Plant





Concepts

- TPG plant produces the thermal base-load
- Chillers & Boilers integrate the TPG and cover the thermal peaks
- Efficient control of the thermal fluxes according to the requests

Main Components

- #3 x 2 Endothermic Gas Engines - MWM
- #1 x 2 Combined Absorber (Hot Water & Exhausts)
- #3 x 2 Engine Covers with heat recovering
- #3 x 2 Heat Pumps


Main Performances

- Engine Electric Pw: 580 kW_e
- Total Electric Pw: 3,480 kW_e
- Engine Heating Pw: 760 kW_t
- Total Heating Pw: 4,560 kW_t
- Absorption Chiller Pw: 1,569 kW_f
- Total Cooling Pw: 3,138 kW_f

UPS capability (for each unit)

- Each unit 800 kW_e
- 3 Engines (redundancy: 2 always running)
- Normal operation mode: 3 Engines at 75% Nominal Power
- Total EE production in operation: 1,200 kW_e
- Free-wheel UPS system (PILLER) 1,100kVA
- Voltage tolerance: ±5%
- Frequency tolerance: ±1%
- Max time range: 15

UPS CONCEPT



Normal Mode Operations

- 3 Gen @ 75%
- Vs ST El. Grid: 1.1MW max
- HQ Load 0.8MW max


Island Mode Operations

- 3 Gen @ xx% according HQ Load
- Vs ST El. Grid: No Link
- HQ Load 0.8MW max

Technical Tolerances Requested

- Max Voltage Variation in static regime: **±1%**
- Max Frequency Variation in static regime: **±1%**
- Max Voltage Variation (under sudden load change above 50%): **±5%**
- Max Frequency Variation (when 100% load under UPS): **±1%**

UPS Scheme: The Island Mode



Rotating UPS System






Fig. 5: Accumulatore inerziale PowerBridge




TGP LAYOUT




Block diagram Trigeneration plant

Mechanical Scheme: 1 Set




TGP Layout: Ground Floor


PIANO TERRA - 1:50



TGP Layout: First Floor



Combined Absorber



■ Acqua di raffreddamento	■ Acqua refrigerata	■ Acqua refrigerante	■ Soluzione diluita
■ Soluzione concentrata	■ Soluzione intermedia	■ Vapore refrigerante	■ Acqua calda

Combined Absorber Chiller




Table of Flue Gas With Hot Water Absorption Chiller Technical Parameters

Model		YRX470(90/79)-149(30/35)H2	
Refrigerating capacity		kW	1490
Chilled water	Inlet/outlet temperature	°C	12/7
	Flux	m ³ /h	256
	Pressure loss	mmH ₂ O	3.5
	Connection diameter (DN)	mm	200
Cooling water	Inlet/outlet temperature	°C	30/35
	Flux	m ³ /h	517
	Pressure loss	mmH ₂ O	7.5
	Connection diameter (DN)	mm	250
Flue gas	Inlet/outlet temperature	°C	470/170
	Flux	kg/h	3X2400
	Pressure loss	mmH ₂ O	165
	Inlet connection diameter (DN)	mm	450
	Outlet connection diameter	mm	650X650
Hot water	Inlet/outlet temperature	°C	88/80
	Flux	m ³ /h	55.2
	Pressure loss	mmH ₂ O	3.5
	Connection diameter (DN)	mm	100
Electrical data	Power supply	3φ -380V -50Hz	
	Total current	A	27.2
	Electric power	kW	8.65
Overall dimensions	Length		4900
	Width	mm	3400
	Height		3575
Shipping weight		t	19.9
Operating weight		t	28.7

Absorption Chiller







Data analysis by Iosto Casula

A different plant management:

- Maximize the use of the thermal energy
- Priority1:Use energy from the Trigeneration System
- Priority2: Use heating first
- Priority3: Use energy locally first
- Priority4: Use the low enthalpy energy from the heat pumps
- Rule1: Use Boilers only if necessary (winter peak load)
- Rule2: Use Chillers only if necessary (summer peak load)
- Dynamic modulation of thermal energy (between heating and cooling) with respect the field loads and the environmental conditions (season, day/night, ...)
- Monitor and verify the plant parameters daily

TGP vs. Energy Requirements



- Interfacing with the old distribution systems
 - TGP based on a variable flux distribution system
 - Old plant is based on a constant flux distribution
- Double cooling system:
 - HVAC (5/7°C)
 - Process (12/15°C)
- Old pipes not well thermal insulated
- Cooling towers (absorption chiller needs more water)
- Old pumps (high EE consumption)

Trigeneration: Costs & Environment Sustainability

2011



Electricity: 49 GWh



Cooling: 28.6 GWh_f



Heating: 6.4 GWh_t

Gas: 4,800,000 Smc

CO₂: 12,984 t

Electricity: 28.6 GWh

CO₂: 19,067 t

Energy Cost
EE: 3,880,000€
Gas: 1,920,000€
Total: 5,800,000€

2011



CO₂: -13,600 t



CO₂: +10,820 t

Total CO₂: -2,780 t (-8%)



Energy Cost
EE: -2,820,000€
Gas: +1,610,000€
Total: -1,220,000€
(-17%)

Thank you for your attention